

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0026:150

Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Simplex, 100 Simplex Dr, Westminster, MA 01441-0001  
Contact: Paul Mattern (978) 731-8542

**DESIGN:** Models 2098-9805, -9806, -9808, -9744 and 4098-9830 remote alarm indicator; Model 4098-9835 remote power/alarm indicator with test switch; Model 2098-9816 remote power/alarm/trouble indicator; Model 4098-9834 remote alarm indicator with test switch. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as remote indicators for use with separately listed compatible detectors and control units. Models 2098-9805, -9806, -9808, -9744, and 4098-9834, -9835 are intended for use with duct smoke detectors. Model 2098-9816 is intended for use with projected beam detector systems.

Reinstated 08-30-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**AUGUST 30, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager